

Wyniki - Zestawienie pomieszczeń

Symbo	Opis pomieszczenia	Ti	Qo	F	Kub.	Qf	Qv	Qp	Qw	N	Vw
1	Pom. biurowe	20	909	17.3	m3	W/m2	W/m3	W	W	1/h	m3/h
2	WC	20	272	4.6	12	59	23	71	201	2.0	24
3	WC	20	721	4.6	12	157	60	520	201	2.0	24
4	Magazyn książek	16	1424	54.2	119	26	12	1017	305	1.0	119
5	Magazyn książek	16	2613	54.2	119	48	22	1986	305	1.0	119
6	Pom. biurowe	20	1439	26.1	68	55	21	1086	266	1.0	68
7	Korytarz	20	684	8.2	21	83	32	600	84	1.0	21
8	Pom. socjalne	20	1409	20.4	53	69	27	795	551	1.5	80
9	Pom. gospodarcze	20	672	5.1	13	132	51	570	52	1.0	13
10	Palarnia	20	344	1.8	5	191	74	246	79	2.0	9
11	Hall	20	1830	54.7	142	33	13	1178	558	1.0	142
12	Wiatrołap	16	595	3.6	9	165	64	529	24	1.0	9
13	Wiatrołap	16	274	2.0	5	137	53	241	13	1.0	5
14	Hall	16	69	4.0	10	17	7	42	27	1.0	10
15	Pokój	20	874	10.8	28	81	31	708	110	1.0	28
16	Łazienka	25	717	3.8	10	189	73	502	200	2.0	20
17	Korytarz	20	127	6.6	17	19	7	60	67	1.0	17
18	Kuchnia	20	661	8.2	21	81	31	427	221	1.5	32
19	Pokój	20	873	16.0	42	55	21	689	163	1.0	42
101	Hall	20	1539	53.8	172	29	9	910	675	1.0	172
102	Wypożyczalnia dla dzieci	20	4306	71.6	229	60	19	3309	898	1.0	229
103	Pokój dyrektora	20	986	17.2	46	57	21	816	182	1.0	46
104	WC	20	347	4.0	11	87	32	173	182	2.0	22
105	WC	20	347	4.0	11	87	32	173	182	2.0	22
106	Pokój administracji	20	1257	21.2	57	59	22	1049	224	1.0	57