

Wyniki - Grzejniki

Numer	Pion	Dzial.	Pom.	Typ grz.	n	L	Gobl	Qwym	Qrz	Qdef	Agz	tz	dt	AG	G
			1	V11-45	12	1.20	911	911	928	-17			[K]		[kg/s]
			2	V11-45	4	0.40	272	272	300	-28	1.000	90.00	27.65	1.00	0.00260
			4	V11-45	8	0.80	709	709	687	22	1.000	90.00	24.26	1.00	0.00676
			4	V11-45	8	0.80	709	709	687	22	1.000	90.00	24.26	1.00	0.00676
			9	V11-45	8	0.80	669	669	634	35	1.000	90.00	23.72	1.00	0.00638
			10	V11-45	4	0.40	343	343	319	24	1.000	90.00	23.27	1.00	0.00327
			11	V11-45	12	1.20	914	914	929	-15	1.000	90.00	25.46	1.00	0.00872
			102	V11-45	14	1.40	1077	1077	1086	-10	1.000	90.00	25.27	1.00	0.01027
			102	V11-45	14	1.40	1077	1077	1086	-10	1.000	90.00	25.27	1.00	0.01027
			102	V11-45	14	1.40	1077	1077	1086	-10	1.000	90.00	25.27	1.00	0.01027
			103	V11-45	12	1.20	988	988	947	41	1.000	90.00	24.00	1.00	0.00943
			104	V11-45	4	0.40	347	347	320	27	1.000	90.00	23.06	1.00	0.00331
			105	V11-45	4	0.40	347	347	320	27	1.000	90.00	23.06	1.00	0.00331
			107	V11-45	16	1.60	1248	1248	1246	1	1.000	90.00	25.01	1.00	0.01190
			107	V11-45	16	1.60	1248	1248	1246	1	1.000	90.00	25.01	1.00	0.01190
			107	V11-45	16	1.60	1248	1248	1246	1	1.000	90.00	25.01	1.00	0.01190
			108	V11-45	12	1.20	1028	1028	956	72	1.000	90.00	23.28	1.00	0.00981
			109	V11-45	12	1.20	1132	1132	1045	87	1.000	90.00	23.12	1.00	0.01080
			109	V11-45	12	1.20	1132	1132	1045	87	1.000	90.00	23.12	1.00	0.01080
			110	V11-45	8	0.80	715	715	688	27	1.000	90.00	24.11	1.00	0.00682
			5	V11-60	12	1.20	1307	1307	1317	-10	1.000	90.00	25.24	1.00	0.01246
			5	V11-60	12	1.20	1307	1307	1317	-10	1.000	90.00	25.24	1.00	0.01246